

TEST REPORT

No.: SHIN180702109CCM

Date: Aug. 01, 2018

Page: 1 of 2

Sample Name

: WALL CLADDING

Product Specification

: 4.5mm Thickness / 128mm Width

Product Material

: Solid Wood Material

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

Test Required

: Pentachlorophenol (PCP)

Test Method

: Please see the next page(s)

SGS Ref. No.

: IN-SH-CP-5612-18095

Date of Receipt

: Jul. 11, 2018

Testing Start Date

: Jul. 11, 2018

Testing End Date

: Jul. 30, 2018

Test result(s)

: For further details, please refer to the following page(s)

(Unless otherwise stated the results shown in this test report refer only to

the sample(s) tested)

Signed for

SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.

Erin Huang

Authorized signatory





TEST REPORT

No. : SHIN180702109CCM

Date: Aug. 01, 2018

Page: 2 of 2

Test item: Pentachlorophenol (PCP)

Test Part Description: Brown board w/ white surface

Test Method: With reference to EN 13986:2004+A1:2015 Clause 5.18 & CEN/TR 14823:2003,

analysis was performed by GC-ECD.

Test Item(s) Unit MDL Result Requirement Conclusion Pentachlorophenol mg/kg 1.0 ND ≤5 Pass Remarks:

(1) 1 mg/kg = 1 ppm = 0.0001%

(2) MDL = Method Detection Limit

(3) ND = Not Detected (< MDL)

(4) "-" = Not Regulated

Sample photo(s):



Note: The test was performed by SGS other internal laboratory.

******* End of report*******



No.89, Block 1159, East Kang Qiao Road, Pudong District, Shanghai, China. 201319 t (88-21) 61196300 f (86-21) 61191853/68163920 www.sgsgroup.com.cn 中国・上海・浦东康桥东路1159弄69号 邮编: 201319 1(86-21)61196300 1(86-21)61191853/681839200 e sus chinaeth