

## **TEST REPORT**

No.: SHIN180702108CCM

Date: Aug. 03, 2018

Page: 1 of 3

Date:

Sample Name

: WALL CLADDING

Product Specification

: 4.5mm Thickness / 128mm Width

Product Material

: Solid Wood Material

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

Test Required

: Formaldehyde Emission (In air)

Test Method

: Please see the next page(s)

SGS Ref. No.

: IN-SH-CP-5612-18095

Date of Receipt

: Jul. 11, 2018

Testing Start Date

: Jul. 11, 2018

Testing End Date

: Aug. 03, 2018

Test result(s)

: For further details, please refer to the following page(s)

(Unless otherwise stated the results shown in this test report refer only to

the sample(s) tested)

Signed for

SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.

Erin Huang

Authorized signatory





## **TEST REPORT**

No.: SHIN180702108CCM

Date: Aug. 03, 2018

Page: 2 of 3

Test item: Formaldehyde Emission (In air)

Test Part Description: Brown wooden board w/ white surface

Test Method: With reference to EN 717-1:2004, analysis was performed by UV-Vis.

Remarks:

(1) 1 mg/kg = 1 ppm = 0.0001%

(2) MDL = Method Detection Limit

(3) ND = Not Detected ( < MDL)

(4) "-" = Not Regulated

Test Item(s) MDL Result Client's requirement Conclusion Unit Formaldehyde Emission (In air) mg/m<sup>3</sup> 0.080 ND E1 Pass

## Notes:

(1) mg/m³ = milligram per cubic meter

(2) Reference Limit: BS EN 13986:2004+A1:2015

Formaldehyde class E1: ≤0.124 mg/m³ air Formaldehyde class E2: >0.124 mg/m³ air






## **TEST REPORT**

No. : SHIN180702108CCM

Date: Aug. 03, 2018

Page: 3 of 3

Sample photo(s):



Note: The test was performed by SGS other internal laboratory.

\*\*\*\*\*\*\* End of report\*\*\*\*\*\*\*

